

B-8

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 65/2025

Dated: 17-03-2025

It is certified that an inspection team headed by ... Sri, Chandrappa D.H.

(Name of Officers with designation) from ... R.D.W.S - Sub-Div, Hirekerur ... PHED

inspected the ... Sri Taralabalu School, Shantidhama, Hirekerur ...

(Name & Address of the school) on ... 09-03-2025 ... (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. ... 65/2025 ... dated ... 15-03-2025

of ... Haveri - Dist - Lab ... (PHED Lab) certified that the

Sri Taralabalu School ... (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till ... 14-10-2025

Signature with Seal: 

Name: Chandrappa D.H.

Designation: Assistant Executive Engineer


Name & Address of the Office / Department: RDWS, SUB-DN HIREKERUR

ASSISTANT EXECUTIVE ENGINEER

RDWS, SUB-DN HIREKERUR


To,
Principal
Sri Taralabalu School, CBSE
Shantidhama, Hirekerur-581 111
Dist: Haveri, Karnataka

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


Administrative officer
Sri Taralabalu Jagadguru
Education Society, SIRIGERE-577541
Chitradurga Dist.




RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
District:Haveri SubDivision: Haveri laboratory

TEST REPORT					
Taluk : Hirekerur, District : Haveri Location : Sri Taralabalu School Shantidhama Hirekerur			Report date: 15/03/25		
			Sample code: 65/2025		
			Date of Sample collection: 09/03/25		
			Analysis start date: 09/03/25		
			Analysis completion date: 14/03/25		
Sample collection protocol: IS 3025(Part-1)			Sample quantity:1000ml		
Sample Particulars: Raw Water			Sample quantity:1000ml		
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description:					
1.	pH Value @Temp°C	7.20	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 1983
2.	Specific Conductance,µS/cm@Temp°C	261	-	-	IS 3025 (Part-14) : 1984
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):1983
5.	Colour, Hazen Units	5	5	15	IS 3025 (Part-4) :1983
6.	Turbidity, NTU	0.2	1	5	IS 3025 (Part-10) : 1984
7.	Total Dissolved Solids@ 105°C, mg/l	136	500	2000	IS 3025 (Part-16) : 1984
8.	Alkalinity as CaCO ₃ , mg/l	128	200	600	IS 3025 (Part-23) : 1986
9.	Total Hardness as CaCO ₃ , mg/l	200.18	200	600	IS 3025 (Part-21) : 2009
10.	Calcium as Ca, mg/l	19.23	75	200	IS 3025 (Part-40) : 1991
11.	Magnesium as Mg, mg/l	36.96	30	100	IS 3025 (Part-46) : 1994
12.	Chloride as Cl, mg/l	69.98	250	1000	IS 3025 (Part-32) : 1988
13.	Sulphate as SO ₄ , mg/l	66.64	200	400	IS 3025 (Part-24) : 1986
14.	Fluoride as F, mg/l	0.148	1	1.5	APHA 23 rd Edition
15.	Nitrate as NO ₃ , mg/l	2.84	45	No relaxation	APHA 23 rd Edition
16.	Iron as Fe, mg/l	0.112	1	No relaxation	IS 3025 (Part-53) : 2003
Remarks: Remarks: The given sample Doesn't/Confirms to the Acceptable/Permissible Limit of IS 10500 : 2012 RA:2018 Drinking Water Specification for The above tested parameter only. The sample supplied by the client (Potable)					
Analysed by: Analyst			Verified by: Assistant Executive Engineer  RDWSD/WQMSP/TeR/01		

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರ್
ಗ್ರಾಮೀಣ ಕುಡಿಯುವ ನೀರು ಮತ್ತು ಸ್ವಚ್ಛತ್ವ
ಇಲಾಖೆ, ಜಾಗ-ವಿಭಾಗ ಹಿರೇಕರೂರು


Administrative officer
Sri Taralabalu Jagadguru
Education Society, SIRIGERE-577541
Chitradurga Dist.